

**ADDENDA #1**

**July 11<sup>th</sup>, 2024**

**ORANGEVALE COMMUNITY CENTER WALKING PATH**

**ORANGEVALE RECREATION AND PARK DISTRICT**

**1. NOTICE TO CONTRACTORS INVITING BIDS**

ITEM 1 – Clarification – The contractor to use the Surety company standard form to complete the bid bond.

ITEM 2 – Clarification – The contractor can connect to the existing fire hydrant for construction use, contractor to provide metered connection and coordinate with the fire department.

ITEM 3 – Clarification – The Sign in sheet from pre-bid

Attachments: Attachment A

**2. BID DOCUMENTS**

ITEM 4 – Geotech Report

Attachments: Attachment B

ITEM 5 – The concrete path should be ADA accessible, contractor need to grade the side ground to 3:1 slope then install sod.

**END OF ADDENDA NO 1**

MTWgroup

Landscape Architecture and Planning

2707 K Street, Sacramento, California 916-369-3990